



Government of West Bengal
Office of the Director General
West Bengal Fire & Emergency Services
13D, Mirza Ghalib Street, Kolkata – 16

Memo No.: FSR/IND/WB/FES/20182019/38993

Date : 07-08-2024

From :
Divisional Fire Officer
Fire Prevention Wing,
West Bengal Fire & Emergency Services

To :
Silver Point School
Premises No. - 31/1, N. C. Roy Chowdhury Road, Kolkata - 700042

Sub : Renewal of Fire Safety Certificate for the occupancy of an existing B+G+IV storied Educational Building in the name & style of " Silver Point School"at premises No. 31/1, N.C. Roy Chowdhury Road, Kolkata 700 042. vide AIN No:- 211912406300000577

This is in reference to your AIN 211912406300000577 dated 22-May-2024 regarding Renewal of Fire Safety Certificate for the occupancy of an existing B+G+IV storied Educational Building in the name & style of " Silver Point School"at premises No. 31/1, N.C. Roy Chowdhury Road, Kolkata 700 042. vide AIN No:- 211912406300000577.

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Renewal of Fire Safety Certificate** for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated maintained.

Recommendation:

1. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the drive way.
2. Entrance/Exits as marked in the sanctioned plan drawing must be open & free from any type of obstruction.



The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912406300000577

3. The Interior finish decoration of the building shall be made with low flame spread material confirming to the I.S. Specification.
 4. To eliminate risk of Fire Hazards, Good Housekeeping both for inside and outside of the building shall be strictly maintained.
 5. Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them.
 6. If required the old electrical lines shall be replaced with new electrical lines, cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
 7. The existing lifts shall be designed as fire lifts for use in case of emergency.
 8. Collapsible lift shall not be allowed.
 9. All fire pumps, alarm & detection system which are incorporated in the building kept in auto mode round the clock.
 10. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable of the building.
 11. The employee and security staff shall be conversant with installed Firefighting equipment of the building and to operate in the event of Fire and Testing.
 12. Mock Fire Practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
 13. Exit signage shall have to be display properly entire the building.
 14. Emergency lighting arrangement shall have to be provided.
 15. Switch gear room, Main & meter area shall be protected with Co2/DCP Fire Extinction conforming I.S. Specification.
 16. First-Aid Fire fighting system shall be provided as per I.S. Specifications.
 17. Arrangement shall have to be made for regular checking, testing and maintenance of all the Fire Fighting installation in the building to keep them to perfectly good working condition at all times.
 18. Periodical flashing of water from the hydrant and hose reel hose shall be done to maintain the efficient working performance of the system.
 19. Sewerage pit covered of all around the building shall have to provide not less than 45 mt.
 20. No obstruction shall have to allow all around driveway of the building like as greenery area, tree & car parking etc.
 21. All floors of electrical ducts shall have to be sealed as per norms.
 22. FCD must be rubber sealed fitted properly.
 23. Temporary tin shaded of the building shall have to be removed within 6 months.
 24. Electrical main & meter room to be maintained all time proper safety measures.
 25. Fire Safety Audit shall be conducted a regular interval and to be recorded in the Fire Prevention Maintenance Register.
 26. Emergency lighting system (battery backup) to be installed in the stair case for the safe evacuation.
 27. A fire control room including a close circuit T.V. system will have to be installed which will observe all the floors of the building.
 28. Floor marking & fire noticed shall have to be display in the building. ,
 29. Fire trained person shall have to be deployed round the clock for any case of exigency.
- This Renewal Fire Safety Certificate is valid for Three years and has to be renewed before expiry of the date of issue of this letter.
- Every three year a certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services, performance of all life & Fire Safety arrangements and installation of the building.

Valid Upto : 06-Aug-2027



Validity unknown

Digitally Signed:
Name: NIHAR BANJAN ROY
Date: 07-Aug-2024 18:15:39
Reason: D-Sign
Location: E-Dist 2.0

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912406300000577